

भारत पेट्रोलियम कॉर्पोरेशन लिमिटेड
ए-5 एब 6, सेक्टर-1, नोएडा-201 301
फोन : 91-539155 फैक्स : 91-532413



BHARAT PETROLEUM CORPORATION LTD.
A-5 & 6, Sector-1, NOIDA - 201 301
Phone : 91-539155, Fax : 91-532413

Date: 18.07.2000

Kind Attn : Mr. Kishore Mansata

Inspection Report dt. 18.07.2000

Refer : P.O. NO. SSP/050797 dt. 15.10.99

Sub : Completed the joint Innd Inspection of MAGNETIC CONDITIONER

Inspection/observation : The chiller machine was opened from bath end. The following observations are made.

1. No scaling is present in the condenser tubes and condenser water line tubes (The circuit on which the Magnetic Water Conditioner is installed) of the chiller machine/HVAC system as on 18.07.2000.

This now completes the Innd joint inspection as per terms of the Purchase Order.

Thanking you,

For MAGNETIZER GROUP

HARI OM TYAGI

For B.P.C.L. A/C Operator

MANZOOR AKHTER