

56C, Mirza Ghalib Street, Calcutta-700016
PH:91-33-2229 2767 MO: 9748727966 / 9331827966
Email: Indiaenergyavr@gmail.com

DEMO SHEET

I
COMPANY NAME Accenture Services Pvt Ltd.
SITE LOCATION Tower B-III, Block B, Unitech Infospace, Newtown, Kolkata
TYPE OF WORK AT LOCATION Office Area

II

AC SPEC.				
S.NO.	BRAND NAME	YEAR	MODEL	CAPACITY
1	<u>Blue Star</u>			<u>2T</u>
2				
3				
4				

III

CLIMATIC CONDITION (FROM MET DEPTT. REPORTS)		
DATE	OUTSIDE TEMPERATURE	CLOUDY/RAIN (Y/N)
<u>4/10/16</u>		<u>N</u>

IV

BYPASS MODE (WITHOUT MAS- ENERGY)								
START				END				TOTAL UNITS CONSUMED (DIFF. OF A & B)
DATE	START TIME	A. METER READING (KWH)	ROOM TEMPERATURE	DATE	END TIME	B. METER READING (KWH)	ROOM TEMPERATURE	
<u>4/10/16</u>	<u>4:35</u>	<u>3.2</u>	<u>27°C</u>	<u>4/10/16</u>	<u>5:35</u>	<u>5.6</u>	<u>21</u>	<u>2.4</u>

V

POWER SAVER MODE (WITH MAS- ENERGY)								
START				END				TOTAL UNITS CONSUMED (DIFF. OF A & B)
DATE	START TIME	A. METER READING (KWH)	ROOM TEMPERATURE	DATE	END TIME	B. METER READING (KWH)	ROOM TEMPERATURE	
<u>4/10/16</u>	<u>5:46</u>	<u>5.9</u>	<u>27°C</u>	<u>4/10/16</u>	<u>6:46</u>	<u>7.4</u>	<u>21</u>	<u>1.5</u>

VI
SAVINGS: 37%
(DIFF. IN TOTAL UNITS CONSUMED IN POWER SAVER MODE AND IN BYPASS MODE)

VII
COMMENTS/OBSERVATIONS IF ANY: Temperature is maintained with & without Energy Saver

CUSTOMER'S SIGNATURE
STAMP
CUSTOMER NAME Debas Das
DESIGNATION CE
CONTACT NO. 9903832172
DATE 4/10/2016

TECH. REP. FOR MAGNATRON INTERNATIONAL
SIGNATURE Basak
NAME Saptak Basak
DATE 4/10/16

NB: CUSTOMER IS REQUESTED TO NOTE ALL METER READINGS AND OTHER RELEVANT RECORDS MENTIONED FOR PROPER VALIDATIONS

ACCENTURE SERVICES PVT LTD.
Infospace SEZ
Plot No. DH-1 B3 & 3/1
NEW TOWN
KOLKATA-700 156
TIME OFFICE